

जिला जल परीक्षण प्रयोगशाला, लोक स्वास्थ्य यांत्रिकी विभाग उपखण्ड शिवपुरी

क्रमांक 05 / जि.प्र. / लो.स्वा.यां. / उपखण्ड / शिवपुरी,

दिनांक 11.09.25

प्रति,

Jack and Jill School
Pohari Road
Shivpuri

विषय:- पीने के पानी की जांच कराने विषयक।

संदर्भ:- आपका पत्र क्रमांक / दिनांक 9.9.25

उपरोक्त विषय एवं संदर्भित पत्रानुसार, आपके भेजे गये जल नमूने की जल परीक्षण रिपोर्ट आपकी ओर अवलोकनार्थ संलग्न प्रेषित हैं।

संलग्न:- जल परीक्षण रिपोर्ट।

प्रयोगशाला प्रभारी
जिला जल परीक्षण प्रयोगशाला
लो.स्वा.यां.विभाग उपखण्ड शिवपुरी
(M.P.)

Public Health Engineering Department Water Testing Laboratory District Shivpuri (M.P.)


Status of Sample	Chemical /Bacteriological Test	Unique Identification No.	86/1	7
Sender's name	By- JACK AND JILL SCHOOL	Sender's letter no.	NIL	
Sender's address	By- JACK AND JILL SCHOOL POHARI ROAD SHIVPURI	Sender's letter date	28/08/2025	0
		Start Date Of Analysis	09/09/2025	0
Quantity of Sample	1 Ltr.	Receipt No.	03	
Sample Collected by	School Staff	End Date Of Analysis	10/09/2025	0


Sample details:

S.No	Distt	Block	Village	Location	source
1	Shivpuri	Shivpuri	Shivpuri	JACK AND JILL SCHOOL POHARI ROAD SHIVPURI	RO Water

Physical/ Chemical /Bacteriological Test Report With Details of Parameters Their Test Methods, Units and Specifications as per BIS.

S. No	Characteristics	Test Method (BIS 10500:2012)	Unit	As per BIS-10500:2012 & Reaffirmed in Sep. 2018		Test Result						
				Require ment (Desirab le Limit)	Permissib le Limit in the absence of Alternate Source	Sample Numbers						
						1	2	3	4	5	6	7
1	2	3	4	5	6	7						
1	Turbidity	BIS :3025 Part 10	NTU	1	5	2.0	-	-	-	-	-	-
2	pH	BIS :3025 Part 11	pH scale	6.5to8.5	<6.5to9.2>	6.8	-	-	-	-	-	-
3	TDS	BIS :3025 Part 16		500	2000	67	-	-	-	-	-	-
4	Total Hardness as CaCO ₃	BIS :3025 Part 21	mg/l	200	600	64	-	-	-	-	-	-
5	Total Alkalinity as CaCO ₃	BIS :3025 Part 23	mg/l	200	600	47	-	-	-	-	-	-
6	Residual chlorine	BIS :3025 Part 26	ppm	0.2	>1.0	Nil	-	-	-	-	-	-
7	Chloride as Cl	BIS :3025 Part 32	mg/l	250	1000	28	-	-	-	-	-	-
8	Calcium as Ca++	BIS :3025 Part 40	mg/l	75	200	16	-	-	-	-	-	-
9	Magnesium as Mg	BIS :3025 Part 46	mg/l	30	100	6.0	-	-	-	-	-	-
10	Iron as F++	BIS :3025 Part 53	mg/l	0.3	1.0	Nil	-	-	-	-	-	-
11	Nitrate as No3	BIS :3025 Part 34	mg/l	45	45	Nil	-	-	-	-	-	-
12	Fluoride as F-	BIS :3025 Part 60	mg/l	1.0	1.5	0.5	-	-	-	-	-	-
13	Total coliform MPN100ml	standard method1992	MPN 100ml	zero	10	0	-	-	-	-	-	-


Signature manager
Authorized Signatory
D. W. T. L. Shivpuri
(M.P.)


Sandhya
Principal
Jack and Jill School
Near Over Bridge, Pohari Road

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 05Dated: 11.09.2025It is certified that an inspection team headed by Rajeev Bhatia(Name of Officers with designation) from Q.M. Lab Incharge Distt Lab ShivpuriPHED inspected the **Jack and Jill School, Near Overbridge, Pohari Road, Shivpuri, Dist.- Shivpuri,****MP** on 10/09/2025 and on the basis of Water Test Report (Attached) bearing no. 03dated 10/09/2025 of Distt. Lab PHED Shivpuri(PHED Lab) certified that the **Jack and Jill School, Near Overbridge, Pohari Road, Shivpuri, Dist.-****Shivpuri, MP** has safe drinking water facilities for the students and members of staff of the

institution. School is also maintains the hygienic sanitation condition in the school building & the

campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 09/09/2026

Signature with seal

:-

DR di:

Name

:-

Designation

:-

Quality manager
D.W.T.L. Shivpuri
(M.P.)

Name & address of the office/Department: -

To,

**Jack and Jill School, Near Overbridge,
Pohari Road, Shivpuri, Dist. - Shivpuri, MP**

(Name and address of the institution)

A. Pandey
Principal
Jack and Jill School
Near Over Bridge, Pohari Road
Shivpuri (M.P.)**Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies**